

SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 1256
Dated 05.06.2023

It is certified that an inspection team headed by
Executive Engineer.

(Name of Officers with designation) from
P.H. DIVISION BHABUA KAJMUR (Name of Department/ Office)

inspected the
HERITAGE GLOBAL SCHOOL

(Name & Address of the school) on 22.05.2023 (date of inspection) and found
that

HERITAGE GLOBAL SCHOOL, KEWA KAJMUR JHARKH

(Name of school) has safe drinking water facilities for the students and members of staff
of the institution and is maintaining the hygienic sanitation condition in the school
building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 12 MONTH -

Signature with Seal: [Signature]

Name: P.H. Division Bhabua

Designation: Executive Engineer

Name & Address of the Office / Department:

To

.....
.....

(Name & Address of the Institution)

Government of Bihar

Public Health Engineering Department

Water Quality Test Monitoring Report (Blanket & 14 Parameters)

Month - May-2023

Sl. No.	Block	Panchayat	Village / Ward	Name of Habitation	Location of Source	Date of Receiving / Sampling	Date of Testing (Final / Completed)	Parameters														Remarks safe or Unsafe
								PH	Turb	TSS	Ca	Mg	Cl	SO ₄	Fe	NO ₃	F	Total Coli				
1	Maner	Jagdish	Khas	Hariyati Ghat Sikhar Khas	Underdrain Well	22/5/2023	24/5/2023	7.8	1	120	8	2.4	10	130	0.1	2	1.0	10	Safe			
Desirable Limit								6.5-8.5	1.0	200	75	30	250	200	0.3	45	1.0					
Permissible limit in absence of alternate source (IS 10500-2012) 2nd revision								6.0	5.0	400	200	10	1000	600	1.0	60	1.5					

Sample Collected by heritage Lodher School Staff

Ranich Kerna
 Signature of Chemist / Lab. Asst.
 Public Health Division, Ehabua 24/5/23

Dinesh Kumar, LA
 24/5/23